

Low carbon heating production





High-temperature Commercial heat pump CO₂ natural refrigerant – Water source – CM range



Up to 90°C hot water production



2 levels of heat in one unit



Simultaneous heating and cooling



High efficiency



Ejector technology



Compact Footprint



Simple / intuitive touch screen / PLC controlled



Connect to BMS, smartphone, tablet, web server, and more



PFAS/TFA free refrigerant

Brochures available here:







| HeatCO₂OL CM WW | | | CM 140WW | CM 170WW | CM 210WW | CM 240WW | CM 270WW | CM350WN |
|--|---------------|-------------|----------------|--------------|----------|----------|----------|---------|
| Nominal point: heating water in | n 30°C, out 6 | 0°C. Cooli | ng water in 12 | 2°C, out 7°C | | | | |
| Heating capacity (water in / out: 30/60°C) | | kW | 140 | 170 | 210 | 240 | 270 | 350 |
| Cooling capacity (water in/out: 12/7°C) | | kW | 110 | 140 | 170 | 195 | 220 | 290 |
| COP | | | 4,0 | 3,9 | 4,0 | 4,0 | 4,0 | 4.0 |
| EER | | | 3,2 | 3,3 | 3,3 | 3,3 | 3,3 | 3.3 |
| Eq. SEER (1) | | | 4,4 | 4,3 | 4,4 | 4,4 | 4,4 | 4.4 |
| Total COP (Cooling and heating) | | | 7,1 | 7,1 | 7,2 | 7,3 | 7,3 | 7.3 |
| Input Power | | kW | 34 | 43 | 52 | 59 | 66 | 86 |
| Flow rate heating 30/60°C | | m³/h | 4 | 5 | 6 | 7 | 8 | 11 |
| Flow rate cooling 12/7°C | | m³/h | 19 | 24 | 29 | 34 | 38 | 50 |
| Nominal point: heating water in | n 30°C, out 7 | 0°C. Cooli | ng water in 12 | 2°C, out 7°C | | | | |
| Heating capacity (water in / out: 30/70°C) | | kW | 140 | 170 | 210 | 240 | 270 | 350 |
| Cooling capacity (water in/out: 12/7°C) | | kW | 105 | 140 | 170 | 195 | 220 | 290 |
| COP | | | 3,8 | 3,7 | 3,8 | 3,8 | 3,8 | 3.8 |
| EER | | | 3,1 | 3,2 | 3,2 | 3,2 | 3,2 | 3.2 |
| Eg. SEER (1) | | | 4,4 | 4,3 | 4,4 | 4,4 | 4,4 | 4.4 |
| Total COP (Cooling and heating) | | | 6,7 | 6,7 | 6,9 | 6,9 | 6,9 | 6.9 |
| Input Power | | kW | 34 | 44 | 53 | 61 | 69 | 90 |
| Flow rate heating 30/70°C | | m³/h | 3 | 4 | 5 | 5 | 6 | 8 |
| Flow rate cooling 12/7°C | | m³/h | 18 | 24 | 29 | 34 | 38 | 50 |
| Physical properties | | | | | | | | |
| Number of compressors | | | 2 | 3 | 3 | 3 | 3 | 4 |
| CO ₂ charge (2) | | kg | 150 | 160 | 160 | 160 | 160 | 180 |
| Connection water side hot | | mm/DN | 35 | 35 | 35 | 42 | 42 | 54 |
| Connection water side cold | | mm/DN | 65 | 65 | 65 | 80 | 80 | 80 |
| | | | Indoor | version* | | | | |
| | L | | 3220 | 3220 | 3220 | 3220 | 3220 | 3820 |
| Dimensions | W | mm | 800 | 800 | 800 | 800 | 800 | 800 |
| | Н | | 1950 | 1950 | 1950 | 1950 | 1950 | 1950 |
| Operationnal weight (CO ₂ + water included) (2) | | kg | 2700 | 2700 | 2700 | 2700 | 2700 | 3000 |
| Sound pressure level @10 m (3) | | dB(A) | 49,5 | 50,4 | 51,3 | 51,3 | 51,8 | 53.4 |
| Electrical data for 400/3/50 + | N/EN/Sho | ort circuit | current 15kA | | | | | |
| Maximum operating current | | Α | 84 | 105 | 126 | 126 | 159 | 212 |
| Nominal electric current | | A | 70 | 83 | 98 | 105 | 120 | 160 |

Heat COOL CM

Main options:

- Outdoor housing version with / without sound proofing
- Hydraulic pumps control
- Modbus, RS485/RTU, TCP communication
- Global electrical energy measurement
- Inverter drive on compressor N°2
- Smart control for several units in parallel
- 2 circuits with different temperature levels of hot water production to maximize performance
- Other options on request

US SEER, we use Directive 2009/15/EC of the European Parliament and of the Council with regard to Ecodesign requirements as areference.

(2) Estimated Value — to be charged and adjusted on site

(3) The sound presure levels are mentioned in free field. Running the equipment in other conditions may lead to different results. The results obtained on the installation site may differ from those in this leaflet, due to sound reflections from walls, etc. The reduction of sound level as a function of distance is theoretical and sound reflection and resonance may alter the results, either on total sound level or on certain frequencies.









More than units produced



Carrier reserves the right to change certain information and specifications contained in this document at any time and without prior notice. Since standards, specifications and designs are subject to occasional change, please ask for confirmation of the information given in this publication

